

Total Firetec Solutions



FIRETEC SINGLECORE



Cert. No. 221c/01

BS6387 CWZ & IEC60331-21 in steel conduit at 950°C (600/1000V).

Emergency lighting cable systems installations.

Fire alarm systems.

BSEN50200 PH120 & BS8434-2 in steel conduit.

FIRETEC STANDARD



Cert. No. 221e/01

APR ID - 1771

'Standard' BS5839-1 26.2(d) Fire Alarms, BS5839-8 Voice Alarms, BS5266-1 8.22.2(a) Emergency Lighting & BS8519 Category 1 Control cable.

BSEN50200 PH30 & Annex E, PH120.

Critical Signal paths – addressable & networked systems.

FIRETEC ENHANCED



Cert. No. 221f/01


APR ID - 1770

'Enhanced' BS5839-1 26.2(e) Fire Alarms, BS5839-8 Voice Alarms, BS5266-1 8.2.2(b) Emergency Lighting & BS8519 Category 1,2 & 3 Control cable.

BSEN50200 PH120 & BS8434-2.

Critical Signal paths – addressable & networked systems.

FIRETEC FRF2



APR ID - 1797


'Enhanced' BS5266-1 8.2.2(b) & (d) Emergency Lighting, BS5839-1 26.2(e) Fire Alarms, BS5839-8 Voice Alarms.

BSEN50200 PH120 & BS8434-2. BSEN60331-3 120 mins.

BS6500 Flex Test 32,000 cycles. Class 5 conductor.

BS8519 Category 1,2 & 3 Control cable.

FIRETEC IMPACT POWER (F120)



Cert. No. 221r/01
Cert. No. 221t/01

APR ID - 1769

Power Cables meeting BS7846 F120, BS8491 120 minutes & BS6387 CWZ.

BS8519 Category 1, 2 & 3 Power & Control applications.

FIRETEC POWER (F2)



Cert. No. 221k/01

APR ID - 1768

Power Cables meeting BS7846 F2 & BS6387 CWZ.

'Enhanced' BS5839-1 26.2(e) Fire Alarms, BS5839-8 Voice Alarm, BS5266-1 8.2.2(b) Emergency Lighting.

BSEN50200 PH120 & BS8434-2.

BS8519 Category 1,2 & 3 Control cable.

AEI LSZH sheathing
compounds are UV stable



Visit our website

Ref: FT-80516